


NOTES:

1. REDUCED PRESSURE BACKFLOW PREVENTER SHALL MEET THE APPROVAL OF THE FOUNDATION FOR CROSS CONNECTION CONTROL AND RESEARCH.
2. FOR CERTIFIED TESTS REQUIRED, SEE DISTRICT REQUIREMENTS.
3. WATER SERVICE WILL NOT BE TURNED ON UNLESS DISTRICT HAS RECEIVED A SATISFACTORY CERTIFIED TEST REPORT AND THE INSULATION MEETS ALL OTHER DISTRICT REQUIREMENTS.
4. IF UNINTERRUPTABLE SERVICE IS REQUIRED, A DUAL R.P.V. ASSEMBLY TO BE INSTALLED.
5. 3" INSTALLATIONS AND ABOVE SHALL BE DUCTILE IRON PIPE.



NO.	REV. DATE	BY
1	OCT. 1992	JO
2	APR. 1994	JO
3	JAN. 1998	BEC
4	DEC. 2003	BEC
5	DEC. 2014	KSB

REDUCED PRESSURE BACKFLOW PREVENTER

APPROVED BY

David McBrath
MANAGER

01/2015
DATE

STANDARD
PLAN

7